

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Rigid Cellular Polystyrene Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

ARABIAN CHEMICAL INSULATION COMPANY

Jebel Ali Free Zone, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C578 - 2018

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



eiaci
مركز الاعتمادات العالمية للاعتماد
Emirates International Accreditation Centre
CB-003-PRD

Certificate No: CL07020028
Valid Until: 30/06/2020



Current Issue Date: 01/07/2019
Original Issue Date: 11/02/2007

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL07020028**

Certificate Issued To:	ARABIAN CHEMICAL INSULATION COMPANY Jebel Ali Free Zone, Dubai, UAE
Applicable Standard Specification:	ASTM C 578 – 18 – Standard Specification for Cellular Rigid Polystyrene Thermal Insulation
Applicable Specific Rules:	DM-DCLD-RD-DP 21-2106 (IC) “Specific Rules for Certification of Rigid Cellular Polystyrene Thermal Insulation as per ASTM C 578 – 18 Through Factory Assessment”.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Rigid Cellular Extruded Polystyrene Thermal Insulation Board CFC Free (see Note 3)	WALLMATE: CW-TG	Size: 1250 x 600 mm & 2500 x 600mm Thickness: 20 - 100 mm ASTM Type IV (as per Table 1)
2	Rigid Cellular Extruded Polystyrene Thermal Insulation Board CFC Free (see Note 3)	FLOORMATE: FM 500 SL-G	Size: 1250 x 600 mm & 2500 x 600mm Thickness: 20 - 100 mm ASTM Type VII (as per Table 1)
3	Rigid Cellular Extruded Polystyrene Thermal Insulation Board CFC Free (see Note 3)	HIGH DENSITY HD 300 SL-G	Size: 1250 x 600 mm & 2500 x 600mm Thickness: 20 - 100 mm ASTM Type V (as per Table 1)
4	Rigid Cellular Extruded Polystyrene Thermal Insulation Board CFC Free (see Note 3)	ROOFMATE: SL	Size: 1250 x 600 mm & 2500 x 600mm Thickness: 20 - 100 mm ASTM Type VI (as per Table 1)
5	Rigid Cellular Extruded Polystyrene Block Insert CFC Free (see Note 3)	STYROFOAM TB	Size: 400 x 200 mm Thickness: 75 mm ASTM Type VI (as per Table 1)

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL07020028**

- NOTE1:** This document forms part of the Certificate of Product Conformity bearing the same certificate number.
NOTE2: The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).
NOTE 3: CFC Free as per declaration from the company, in accordance with the 2017 Al Sa'fat Dubai Green Building Evaluation System.

**TABLE 1 (EXTRUDED)
PHYSICAL PROPERTY REQUIREMENTS OF RIGID CELLULAR
POLYSTYRENE THERMAL INSULATION**

S N	PROPERTIES	TYPE XII	TYPE X	TYPE XIII	TYPE IV	TYPE VI	TYPE VII	TYPE V
1	COMPRESSIVE RESISTANCE @ yield or 10% deformation, which occurs first, min kPa	104	104	138	173	276	414	690
2	THERMAL RESISTANCE of 25.4 mm thickness, @ mean temp. 35°C and 60% RH min, K-m ² /W	0.77	0.84	0.65	0.84	0.84	0.84	0.84
3	THERMAL CONDUCTIVITY , max, W/m·K @ 35°C and 60% RH	0.0330	0.0303	0.0392	0.0303	0.0303	0.0303	0.0303
4	FLEXURAL STRENGTH , min, kPa	276	276	310	345	414	517	690
5	WATER VAPOR PERMEANCE of 25.4 mm thickness, max, perm	1.5	1.5	1.5	1.5	1.1	1.1	1.1
6	WATER ABSORPTION by total immersion, max volume %	0.30	0.30	1.0	0.30	0.30	0.30	0.30



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL07020028**

7	DIMENSIONAL STABILITY (change in dimension), max, %	2.0	2.0	2.0	2.0	2.0	2.0	2.0
8	OXYGEN INDEX , min, volume %	24	24	24	24	24	24	24
9	DENSITY , min, kg/m ³	19	21	26	23	29	35	48

NOTE: THE ABOVE SPECIFICATION VALUES ARE EXTRACTED FROM TABLE 1 OF ASTM C578-18

Original Issue Date : 11 February 2007

Current Issue Date : 01 July 2019

Valid Until : 30 June 2020

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department