

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

ARABIAN PROFILE COMPANY LIMITED

P.O. Box 3195, Sharjah, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 13165: 2012

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL07020033
Valid Until: 28/11/2019



Current Issue Date: 29/11/2018
Original Issue Date: 17/05/2007

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION REV 01
FOR CERTIFICATE NO. CL07020033**

Certificate Issued To:	ARABIAN PROFILE COMPANY LIMITED P.O. Box 3195, Sharjah, UAE
Applicable Standard Specification:	BS EN 13165:2012–Thermal insulation products for buildings – Factory made rigid polyurethane foam (PUR) products - Specification
Applicable Specific Rules:	DM-DCLD-RD-DP21-2124 (IC) “Specific Rules for Certification of Factory Made Polyurethane Rigid Foam Thermal Insulation (as per BS EN 13165:2012) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Factory made rigid polyurethane (PUR) foam CFC Free <i>(See Note 2)</i>	ARABIAN PROFILE	<p>Polyurethane (PUR) Insulation Foam</p> <p>Nominal Thickness - 35 mm (min) for wall and 50 mm (min) for roof; Length (max) - 14 meters ; Nominal Width - 1000 mm; Apparent Density 35 kg/m³ (min); Thermal conductivity (max) – initial value of 0.027 W/(m*K) and aged value of 0.030 W/(m*K) <i>(See Note 1)</i></p> <p>Code: PUR-EN 13165-T2-DS(TH)1-CS(10/Y)100 – mu 318.63 – 32.32 - Zi 22.76 – 2.31</p> <p>Manufactured with corrugated aluminum or Metal/Steel sheet facing either on one side or both sides to be used as thermal insulation sandwich panel.</p>



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION REV 01
FOR CERTIFICATE NO. CL07020033**

- Note 1: Maximum k-value measured at 35°C temperature and 60% relative humidity condition*
- Note 2: In compliance with clause 701.01 (1) of the 2017 Al Sa'fat– Dubai Green Building Evaluation System*
- Note 3: This certification covers only the PUR foam within the panel*
- Note 4: This document forms part of the Certificate of Product Conformity bearing the same certificate number*
- Note 5: The above products shall bear the DCL Conformity Mark applied on each individual product.*
- Note 6: The revision was made due to the separation of Fire Safety requirements from Al Sa'fat Certification requirements*
- Note 7: This supersedes the scope of certification issued on 29 November 2018*

Original Issue Date : 17 May 2007
Current Issue Date : 24 March 2019
Valid Until : 28 November 2019

ARIF HUSAIN AL MARZOOQI
Products Conformity Assessment Section Manager
Dubai Central Laboratory Department