

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Mineral Wool Insulation

(Details as per the attached Scope of Certification)

manufactured by:

SAUDI ROCKWOOL FACTORY CO.

P.O. Box:145 Riyadh 11383 Kingdom of Saudi Arabia

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 13162: 2012

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



eiaci
مركز الاعتمادات العالمية للاعتماد
Emirates International Accreditation Centre
CB-003-PRD

Certificate No: CL10020131
Valid Until: 04/04/2020



Current Issue Date: 05/04/2019
Original Issue Date: 05/04/2010

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL10020131**

Certificate Issued To:	SAUDI ROCKWOOL FACTORY CO. P.O. Box:145 Riyadh 11383 Kingdom of Saudi Arabia
Applicable Standard Specification:	BS EN 13162:2012 – Thermal Insulation Products for Buildings – Factory Made Mineral Wool (MW) Products - Specification
Applicable Specific Rules:	RD-DP21-2130 (IC) “Specific Rules for Certification of Factory Made Mineral Wool Thermal Insulation Products (as per BS EN 13162:2012) Through Factory Assessment”.

S/N	Product Description	Product Brand	Product Details
1	Mineral Wool (Rockwool) Panel (CFC Free)*	Saudi Rockwool	Rockwool Panel Without Facing Nominal Thickness, 25-150 mm 1. Nominal Density, 30 – 40 kg/m ³ ; k-value: 0.048 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)0.5-WS-WL(P)-MU3 2. Nominal Density, 41 – 60 kg/m ³ ; k-value: 0.044 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)0.5-WS-WL(P)-MU3 3. Nominal Density, 61 – 120 kg/m ³ ; k-value: 0.042 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)5-WS-WL(P)-MU3 4. Nominal Density, 121 – 160 kg/m ³ ; k-value: 0.042 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)10-WS-WL(P)-MU3
		Saudi Rockwool	Rockwool Panel with Alu-Foil Facing Nominal Thickness, 25-150 mm 1. Nominal Density, 30 – 40 kg/m ³ ; k-value: 0.048 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)0.5-WS-WL(P)-Z3 2. Nominal Density, 41 – 60 kg/m ³ ; k-value: 0.044 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)0.5-WS-WL(P)-Z3 3. Nominal Density, 61 – 120 kg/m ³ ; k-value: 0.042 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)5-WS-WL(P)-Z3 4. Nominal Density, 121 – 160 kg/m ³ ; k-value: 0.042 W/(m•K) MW-EN13162-T3-DS(TH)-CS(10)10-WS-WL(P)-Z3



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL10020131**

		Saudi Rockwool	Rockwool Panel with Fiber Glass-Veil Facing Nominal Thickness, 25-150 mm 1. Nominal Density, 30 – 40 kg/m ³ ; k-value: 0.048 W/(m·K) MW-EN13162-T3-DS(TH)-CS(10)0.5-WS-WL(P)-MU5 2. Nominal Density, 41 – 60 kg/m ³ ; k-value: 0.044 W/(m·K) MW-EN13162-T3-DS(TH)-CS(10)0.5-WS-WL(P)-MU5 3. Nominal Density, 61 – 120 kg/m ³ ; k-value: 0.042 W/(m·K) MW-EN13162-T3-DS(TH)-CS(10)5-WS-WL(P)-MU5 4. Nominal Density, 121 – 160 kg/m ³ ; k-value: 0.042 W/(m·K) MW-EN13162-T3-DS(TH)-CS(10)10-WS-WL(P)-MU5
2	Mineral Wool (Rockwool) Mattress (CFC Free)*	Saudi Rockwool	Rockwool Mattress with Alu-Foil Facing Nominal Thickness, 25-120 mm MW-EN13162-T3-DS(TH)- WS-WL(P)-Z3 1. Nominal Density, 30 – 40 kg/m ³ ; k-value: 0.048 W/(m·K) 2. Nominal Density, 41 – 60 kg/m ³ ; k-value: 0.044 W/(m·K) 3. Nominal Density, 61 – 100 kg/m ³ ; k-value: 0.042 W/(m·K)
		Saudi Rockwool	Rockwool Mattress with Mesh-Wire Facing Nominal Thickness, 25-150 mm MW-EN13162-T3-DS(TH)- WS-WL(P)-MU3 Nominal Density, 70 – 120 kg/m ³ ; k-value: 0.042 W/(m·K)

Note 1: Maximum k-value measured at 35°C temperature and 60% relative humidity condition

Note 2: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

Note 3: The above products shall bear the DCL Conformity Mark (applied on each product or on the packaging).

Note 4: * In compliance with Clause 701.01 (1) of the Green Building Regulations & Specifications.

Original Issue Date : 05 APRIL 2010
 Current Issue Date : 05 APRIL 2019
 Valid Until : 04 APRIL 2020

ARIF HUSAIN AL MARZOOQI
 Products Conformity Assessment Section Manager
 Dubai Central Laboratory Department