

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,

hereby attests that the product(s)

LOW-RELAXATION, SEVEN-WIRE STEEL STRAND FOR PRESTRESSED CONCRETE

(Details as per the attached Scope of Certification)

manufactured by:


GLOBAL OVERSEAS GROUP CORP. LTD.

High-Tech Industrial Park Area, Yantai, Shangdong, China

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM A416/416M-15

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark to the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN

Director, Dubai Central Laboratory Department

Dubai Municipality

Verify:



Certificate No: CL12020166

Valid Until: 07 August 2019



Current Issue Date: 08 August 2018

Original Issue Date: 08 August 2012

DM-DCLD-F-IC-2031 REV 13

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this Certificate.

This Certificate is an electronic document, subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL12020166**

Certificate Issued To: **GLOBAL OVERSEAS GROUP CORP. LTD.**
High-Tech Industrial Park Area, Yantai, Shandong Province,
China.

Applicable Standard Specification: ASTM A 416/A 416 M –15 Standard Specification for Low
Relaxation, Seven-Wire Steel Strand for Prestressed Concrete.

Applicable Specific Rules: RD-DP21-2131 (IC) “Specific Rules for Certification of
Steel Strand, Uncoated Seven Wire for Prestressed
Concrete (as per ASTM A 416/A 416 M –15) Through
Factory Assessment”.

S/N	Product Description	Nominal Diameter (mm)	Product Details
1	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	9.53	Seven-Wire Low relaxation steel strand grade 1860[270] with nominal diameter 9.53mm, minimum Breaking Strength of 102 kN.
2	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	12.7	Seven-Wire Low relaxation steel strand grade 1860[270] with nominal diameter 12.7mm, minimum Breaking Strength of 184 kN.
3	Steel Strand, Un-Coated Seven-Wire for Prestressed Concrete	15.2	Seven-Wire Low relaxation steel strand grade 1860[270] with nominal diameter 15.2mm, minimum Breaking Strength of 261 kN.

NOTE1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).

Original Issue Date : 08 August 2012

Current Issue Date : 08 August 2018

Valid Until : 07 August 2019

ARIF HUSAIN AL MARZOOQI

Director of Products Conformity Assessment Section

Dubai Central Laboratory Department