

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Mineral Fiber Pipe Insulation

(Details as per the attached Scope of Certification)

manufactured by:

FUJAIRAH ROCKWOOL FACTORY

P.O. BOX 211, AL HAYL INDUSTRIAL AREA, FUJAIRAH, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C547 - 2012

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL14020234
Valid Until: 06/12/2019



Current Issue Date: 07/12/2018
Original Issue Date: 07/12/2014

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL14020234

Certificate Issued To:	FUJAIRAH ROCKWOOL FACTORY P.O. Box: 211 Fujairah, U.A.E.
Applicable Standard Specification:	ASTM C 547-12 Standard Specification for Pipe Thermal Insulation
Applicable Specific Rules:	RD-DP21-2108 (IC) "Specific Rules for Certification of Mineral Fiber Pipe Thermal Insulation (ASTM C 547-12) Through Factory Assessment".

S/N	Product Description	Product Brand	Product Details
1	Mineral Rockwool Pipe Thermal Insulation (CFC Free)*	Fujairah Rockwool (CXXX)	Type II without facing Nominal Density, 80-180 kg/m ³ Diameter, 21 mm – 610 mm Thickness, 25 - 120 mm Flame Spread Index less than 25 and Smoke Developed Index less than 50 (see note 1)
		Fujairah Rockwool (C2XX)	Type II with Aluminum foil facing Nominal Density, 80-180 kg/m ³ Diameter, 21mm – 610 mm Thickness, 25 - 120 mm Flame Spread Index less than 25 and Smoke Developed Index less than 50 (see note 1)

Note 1: This product is complying with "UAE Fire and Life Safety Code of Practice 2017" according to the DCD certificate No. SM 9

Note 2: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

Note 3: The above products shall bear the DCL Conformity Mark (applied on each product or on the packaging).

Note 4: * In compliance with clause 701.01 (1) of the 2017 AL SA'FAT – DUBAI GREEN BUILDING EVALUATION SYSTEM

Original Issue Date : 07 December 2014

Current Issue Date : 07 December 2018

Valid Until : 06 December 2019

ARIF HUSAIN AL MARZOOQI
Products Conformity Assessment Section Manager
Dubai Central Laboratory Department