

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:


SUPREME WATER PROOFING & INSULATION (LLC)

P.O. BOX 181672 DUBAI, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL16020393
Valid Until: 27/08/2019



Current Issue Date: 28/08/2018
Original Issue Date: 28/08/2016

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL16020393

Certificate Issued To: SUPREME WATER PROOFING & INSULATION
P.O. BOX 181672 DUBAI, UAE

Applicable Standard Specification: EN 14315-1:2013 – Thermal Insulating Product for Buildings – In situ Formed Sprayed Rigid Polyurethane (PUR) and PIR Foam Products

Applicable Specific Rules: DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of In-Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per EN14315-1:2013) Through Factory Assessment”.

| S/N | PRODUCT DESCRIPTION | BRAND NAME | PRODUCT DETAILS |
|-----|---|---|--|
| 1 | In-Situ Formed Sprayed Polyurethane (PUR) Foam Products “CFC Free” * | SUPREME GREEN INSULATION & COMBO ROOF CARE SYSTEM | Min. Density : 35 kg/m ³ Thickness = 32 mm (min.) k-value: 0.024 W/(K-m) @ 35 °C & 60% RH With a minimum Compressive Strength of 100 kPa Dimensional Stability DS(TH)1 Product Code: PU EN14315-1- DS(TH)1-CS(10/Y)100-MU30 |

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL16020393

NOTE1: *This document forms part of the Certificate of Product Conformity bearing the same certificate number.*

NOTE 2: **CFC Free as per declaration from the company, in accordance with the 2017 Al Sa'fat Green Building Evaluation System.*

NOTE 3: *This certification is applicable only to spray-applied foam insulation used as part of combo-roofing system wherein the insulation material layer is fully covered by concrete layer. Accordingly there is no requirement for testing the fire safety requirements as per clause [6.3.8] of the UAE Fire and Life Safety Code of Practice 2018.*

Original Issue Date : 28 August 2016

Current Issue Date : 28 August 2018

Valid Until : 27 August 2019

ARIF HUSAIN AL MARZOOQI
Products Conformity Assessment Section Manager
Dubai Central Laboratory Department