

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,

hereby attests that the product(s)

In-Situ FORMED SPRAYED POLYURETHANE (PUR) FOAM

(Details as per the attached Scope of Certification)

manufactured by:


AL KHUMASIYYA CONSTRUCTIONS & INSULATION MATERIALS

Saif Mohd Mussad Al Murry Bldg. Mezzanine Floor-3, P.O. Box 73729, Abu Dabi, U.A.E.

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1:2013

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark to the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN

Director, Dubai Central Laboratory Department

Dubai Municipality

Verify:



Certificate No: CL17020471

Valid Until: 03 July 2019



Current Issue Date: 04 July 2018

Original Issue Date: 04 July 2017

DM-DCLD-F-IC-2031 REV 13

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this Certificate.

This Certificate is an electronic document, subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL17020471**

Certificate Issued To	AL KHUMASIYYA CONSTRUCTIONS & INSULATION MATERIALS Saif Mohd Mussad Al Murry Bldg, P.O. Box 73729, Abu Dabi, U.A.E.
Applicable Standard Specification:	EN 14315-1 :2013 – Thermal insulating products for buildings – In situ formed sprayed polyurethane (PUR) and Polyisocyanurate (PIR) foam products
Applicable Specific Rules:	RD-DP21-2187 (IC) “Specific Rules for Certification of In Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per BS EN14315-1:2013) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	In-Situ Formed Sprayed Polyurethane (PUR) Foam Products “CFC Free” **	KUMAT COMBO	Core Density : 40 kg/m ³ Min. Thickness = 35 mm Thermal Conductivity: 0.029 W/(K·m)* (max) With a minimum Compressive Strength of 100 kPa Dimensional Stability DS(TH)2 Product Code: PU EN14315-1-DS(TH)2-CS(10/Y)100-MU(25)

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: * Maximum k-value measured at 35°C temperature and 60% relative humidity Condition.

NOTE 3: ** CFC Free as per declaration from the company, in compliance with Clause 701.01 (1) of the Al Sa'fat Green Building Evaluation System.

NOTE 4: This certification is applicable only to spray-applied foam insulation used as part of combo-roofing system wherein the insulation material layer is fully covered by concrete layer. Accordingly there is no requirement for testing the fire safety requirements as per clause [6.3.8] of the UAE Fire and Life Safety Code of Practice 2017.

Original Issue Date : 04 July 2017

Current Issue Date : 04 July 2018

Valid Until : 03 July 2019

ARIF HUSAIN AL MARZOOQI

Head of Products Conformity Assessment Section
Dubai Central Laboratory Department