

## CERTIFICATE OF PRODUCT CONFORMITY

*Dubai Central Laboratory Department (DCLD) of Dubai Municipality,*

*hereby attests that the product(s)*

**IN-SITU FORMED SPRAYED POLYURETHANE (PUR) FOAM PRODUCTS**

*(Details as per the attached Scope of Certification)*

*manufactured by:*


**PLUS PREMIER TECHNICAL SERVICES LLC.**

**P.O. BOX 390145, Dubai, U.A.E.**

*have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:*

**BS EN 14315-1: 2013**

*Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark to the above-mentioned product(s).*



**for / ENGR. AMIN AHMED AMIN**

**Director, Dubai Central Laboratory Department**

**Dubai Municipality**

Verify:



**Certificate No: CL17020490**

**Valid Until: 30 July 2019**



**Current Issue Date: 31 July 2018**

**Original Issue Date: 31 July 2017**

DM-DCLD-F-IC-2031 REV 13

*The attached Scope of Certification bearing the same Certificate No. forms an integral part of this Certificate.*

*This Certificate is an electronic document, subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.*

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL17020490**

**Certificate Issued To** : **PLUS PREMIER TECHNICAL SERVICES LLC.**  
P.O. Box 390145, Dubai, UAE

**Applicable Standard Specification:** **EN 14315-1 :2013** – Thermal insulating products for buildings – In situ formed sprayed polyurethane (PUR) and Polyisocyanurate (PIR) foam products

**Applicable Specific Rules:** **RD-DP21-2187 (IC)** “Specific Rules for Certification of In Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per BS EN14315-1:2013) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	In-Situ Formed Sprayed Polyurethane (PUR) Foam Products “CFC Free” **	COMBO ROOF PLUS	<b>In Situ Formed Sprayed PUR Insulation Foam</b> Core Density = 40kg/m <sup>3</sup> Thickness = 30 to 150 mm Thermal Cond. (max) age value* - 0.028 W/(m*K) @ 35 °C & 60% RH Minimum Compressive strength of 100 KPa Dimensional Stability DS(TH)1 Min. Water Vapor transmission factor, $\mu$ = 30 Code : PU-EN 14315 -1-DS(TH)1 –CS(10/Y)100- $\mu$ 30

**NOTE 1:** This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

**NOTE 2:** \* Maximum k-value measured at 35°C temperature and 60% relative humidity Condition.

**NOTE 3:** \*\* CFC Free as per declaration from the company, in compliance with Clause 701.01 (1) of the 2017 Al Sa'fat Dubai Green Building Evaluation System..

---

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL17020490**

*NOTE 4: This certification is applicable only to spray-applied foam insulation used as part of combo-roofing system wherein the insulation material layer is fully covered by concrete layer. Accordingly there is no requirement for testing the fire safety requirements as per clause [6.3.8] of the UAE Fire and Life Safety Code of Practice 2017.*

*Original Issue Date : 31 July 2017*

*Current Issue Date : 31 July 2018*

*Valid Until : 30 July 2019*



**ARIF HUSAIN AL MARZOOQI**  
Products Conformity Assessment Section Manager  
Dubai Central Laboratory Department