

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,

hereby attests that the product(s)

IN-SITU FORMED SPRAYED APPLIED POLYURETHANE (PUR) FOAM

(Details as per the attached Scope of Certification)

manufactured by:


JOHNSONCO CONTRACTING LLC

1st Industrial Street, Industrial Area 2, Sharjah, UAE

have been assessed in accordance with DCLD Document Ref. No. RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark to the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN

Director, Dubai Central Laboratory Department

Dubai Municipality

Verify:



Certificate No: CL18020585

Valid Until: 26 May 2019



Current Issue Date: 27 May 2018

Original Issue Date: 27 May 2018

F-IC-2031 REV 12

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this Certificate.

This Certificate is an electronic document, subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020585**

Certificate Issued To: **JOHNSONCO CONTRACTING LLC**
1ST Industrial Street, Industrial Area 2, Sharjah, UAE

Applicable Standard Specification: **EN 14315-1:2013** – Thermal Insulating Product for Buildings
In-situ Formed Sprayed Rigid Polyurethane (PUR) and PIR
Foam Products

Applicable Specific Rules: **RD-DP21-2187 (IC)** “Specific Rules for Certification of In-Situ
Formed Sprayed Polyurethane and Polyisocyanurate Foam
Products (as per EN14315-1:2013) Through Factory
Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Spray-Applied Rigid Polyurethane (PUR) Foam Products “CFC Free” *	JOHNSONCO COMBO ROOFING SYSTEM	Min. Density : 35 kg/m ³ Thickness: 30-150 mm k-value: 0.025 W/(K·m)* (max) @ 35°C & 60% RH With a min. Compressive. Strength of 100 kPa Dimensional Stability (DS(TH)2 Short term water absorption by partial immersion: 0.1 kg/m ² (max) Product Code: PU EN14315-1-DS(TH)2-CS(10/Y)100- MU(25)

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCL Conformity Mark.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020585**

NOTE 3: **CFC Free as per declaration from the company, in accordance with the 2017 Al Sa'fat – Dubai Green Building Evaluation System*

NOTE 4: *Applicable only to In Situ Formed Sprayed PUR Insulation Foam used as part of combo-roofing system where in the insulation material layer is fully covered by concrete layer. Accordingly there is no requirement for testing the fire safety requirements as per clause [6.3.8] of the UAE Fire and Life Safety Code of Practice 2017.*

Original Issue Date : 27 May 2018

Current Issue Date : 27May 2018

Valid Until : 26 May 2019



ARIF HUSAIN AL MARZOOQI

Head of Products Conformity Assessment Section

Dubai Central Laboratory Department