

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality,

hereby attests that the product(s)

LOW EMITTING MATERIALS (COATING, SEALANT AND ADHESIVE)

(Details as per the attached Scope of Certification)

Manufactured by:


COLMEF BUILDING MATERIALS SPECIALITIES LLC

P.O.BOX 32757 - Dubai, U.A.E

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 Al Sa'fat Dubai Green Building Evaluation System

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark to the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN

Director, Dubai Central Laboratory Department

Dubai Municipality

Verify:



Certificate No: CL18020607

Valid Until: 06 July 2019



Current Issue Date: 07 July 2018

Original Issue Date: 07 July 2018

DM-DCLD-F-IC-2031 REV 13

The attached Scope of Certification bearing the same Certificate No. forms an integral part of this Certificate.

This Certificate is an electronic document, subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020607**

Certificate Issued To: COLMEF BUILDING MATERIALS SPECIALITIES LLC
P.O.BOX 32757 – DUBAI, UNITED ARAB EMIRATES

Applicable Standard Specification: 2017 Al Sa'fat Dubai Green Building Evaluation System

Applicable Specific Rules: DM-DCLD-RD-DP21-2180 (IC) Specific Rules for Certification of Paints through Factory Assessment as per the 2017 Al Sa'fat - Dubai Green Building Evaluation System

S/N	Product Description	Brand Name	Product Details
1	One pack performance coatings	Mantlocolor w , Kretesil , Asfabit RB , Bituflex Plus , Cemcoat , Asfabit , Asfabit RB+ , Asfabit RB , Asfabit RBL , Asfabit RBL+ , Acrilux , Mantoflex , Elastogum , Epopfloor ACR, Betohard L	Water Base Coating for Roof Coating/Coating Applied to Hardscapes VOC (GBRS limit is max. 140 g/l) White Color (Note 3) <i>SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”</i>
2	One pack performance coatings	Elastothane TR , Epopfloor LM , Conseal , Bituflex , Murex , Elastothane WP1 , Elastothane TR , Elastothane 100 , Elastothane 400 , Mantocolor S , Acryfil , Epopfloor E 100 , Epopfloor P 380 , Epopfloor P 500	Solvent Base Coating for Roof Coating/Coating Applied to Hardscapes VOC (GBRS limit is max. 500 g/l) White Color (Note 3) <i>SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”</i>

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020607**

3	Two pack reactive performance coatings for specific end use such as floors	<p>Epofloor E 250 , Epofloor E 240 , Epofloor SLE 25 , Mantobrush , Kretesil NT , Kretesil CR , Idrolastic , Cemcoat FX1 , Cemcoat FX2 , Elastothane WP2 , Epochim PWT , Epochim K 40 , Epochim K 100 , Epochim EPS , Epossitar 100 , Epofloor FC , Epofloor E 2000 , Epofloor SLE 40 , Epofloor SLE 50 , Epofloor E 250 IF , Epofloor SL IF , Epofloor SL FC , Epofloor SC IF , Epofloor SL FCT , Epofloor SL IFT , Epofloor ECT , Epofloor P 200 , Epofloor P 320 , Epofloor P 360 , Epofloor SLP 25 , Epofloor SLP 50 , Epofloor SLU , Epofloor TX , Epofloor HM , Epofloor CF , Epofloor HC , Uramasseto M1 , Uralevello</p>	<p>Water Base Coating (Solvent Free) for Roof Coating/Coating Applied to Hardscapes</p> <p>VOC (GBRS limit is max. 140 g/l)</p> <p>White Color (Note 3)</p> <p><i>SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”</i></p>
4	Two pack reactive performance coatings for specific end use such as floors	<p>Elastothane TR2 , Epofloor UV2 , Epossitar 70 , Epofloor P 125 , Epofloor P 440 , Epofloor UV3 , Colmefoam HD</p>	<p>Solvent Base Coating for Roof Coating/Coating Applied to Hardscapes</p> <p>VOC (GBRS limit is max. 500 g/l)</p> <p>White Color (Note 3)</p> <p><i>SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”</i></p>

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020607**

5	Primer	Primer PU , Primer Poxo	Solvent Base Primer for Roof Coating/Coating Applied to Hardscapes VOC (GBRS limit is max. 750 g/l) White Color (Note 3) <i>SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”</i>
6	Primer	Primer Poxo FF , Primer Poxo PU , Primer Poxo FC , Primer Poxo IF , Primer Poxo WB , Ureaprime W	Water Base Primer(Solvent Free) for Roof Coating/Coating Applied to Hardscapes VOC (GBRS limit is max. 30 g/l) White Color (Note 3) <i>SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”</i>
7	Ceramic Tile Adhesive	Neofil F7 , Neofil F7* , Neofil F8 , Neofil F8* , Maxicol , Maxicol T50 , Silikoll , Neofil F10 , Neofil F15 , Neofil P8	Ceramic Tile Adhesive VOC (GBRS limit is max. 65 g/l)
8	Multipurpose Construction Adhesive	Neofil M10 , Neofil F 50 , Neofil F 50 Flex , Neofil F 60 , Adercol , Silikrete , Arredo Colla , Poxycol WB , Poxycol	Multipurpose construction Adhesive VOC (GBRS limit is max. 65 g/l)
9	Architectural Sealant	Acryseal , Elastoseal PS , Elastoseal PU 40 , Elastoseal PU 25 , Elastoseal PU , Elastoseal EPU , Elastoseal CTP , Conmastic	Architectural Sealant VOC (GBRS limit is max. 250 g/l)

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020607**

NOTE1: *This document forms part of the Certificate of Product Conformity bearing the same certificate number.*

NOTE2: *The above product shall bear the DCL Conformity Mark.*

NOTE3: *For colors/types not covered by the Scope, SRI and LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the Requirements of the DM-GBRS.*

SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”


SRI Class 2 ($29 < 78$) - “Can be Used in 75 - 100% of surface to be coated – Sloped Roof”

SRI Class 3 (< 29 or untested) – “Can be Used in 0 – 25% of surface to be coated – Sloped or Flat Roof provided the remaining area is Class 1 or 2”

LRV Class 1 (≥ 45) – “Can be used in 75-100% of surface to be /painted/coated”

LRV Class 2 (< 45 or untested) – “Can be used in 0-25% of surface to be painted/coated provided the remaining area is Class 1”.

Original Issue Date : 07 July 2018
Current Issue Date : 07 July 2018
Valid Until : 06 July 2019



ARIF HUSAIN AL MARZOOQI
Head of Products Conformity Assessment Section
Dubai Central Laboratory Department