

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials (Paints, Coatings, Adhesives, Sealants)

(Details as per the attached Scope of Certification)

manufactured by:

STONCOR MIDDLE EAST LLC
AL QOUZ INDUSTRIAL AREA 3

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL18020630
Valid Until: 24/09/2019



Current Issue Date: 25/09/2018
Original Issue Date: 25/09/2018

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020630**

Certificate Issued To	STONCOR MIDDLE EAST LLC P.O. BOX 3034, Al Qouz Industrial Area 3 Dubai, UAE
Applicable Standard Specification:	2017 Al Sa'fat Dubai Green Building Evaluation System
Applicable Specific Rules:	RD-DP21-2180-(IC) Specific Rules for FA Certification of Low Emitting Materials as per Al Sa'fat – Dubai Green Building Evaluation System

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Binding Primer	Deckshield SF	Solvent Base for Interior/Exterior Application VOC (max. 750 g/l)
2	One Pack Performance Coating	Deckshield Concrecoat	Water Base for Interior/Exterior Application VOC (max. 140 g/l)
3	Two Pack Reactive Performance Coating for Specific End such as floor	Prostruct WB Clear	Water Base for Interior/Exterior Application VOC (max. 140 g/l)
		Deckshield UV	Solvent Base for Interior/Exterior Application VOC (max.500 g/l) Color: Light Gray SRI Class 2 - can be used in 75-100 5% surfaced to be coated - Sloped Roof Color: Dark Gray SRI Class 3 - can be used in 0-25% surfaced to be coated - Sloped or Flat
		Deckshield Finish	
		Deckshield ED Membrane	
		Stonclad GS	
		Deckshield Linemarker	
		Deckshield Putty	
		Stonclad HT	
		Stonclad UT	
		Stonclad UR	
		Stonkote GS4	
Stonkote HT4			

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020630**

		Stonglaze E4	Roof <i>(See Note 2)</i>
		Urethane Primer	
		Standard Primer	
		HT Primer	
		Carboguard 1340	
		Carbothane 133HB	
		Prostruct 959	
		Prostruct 959 SL	

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: For colors/types not covered by the Scope, SRI and LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of Al Sa'fat.

SRI Class 1 (≥ 78) – "Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof"

SRI Class 2 (29<78) - "Can be Used in 75 - 100% of surface to be coated – Sloped Roof"

SRI Class 3 (< 29 or untested) – "Can be Used in 0 – 25% of surface to be coated – Sloped or Flat Roof provided the remaining area is Class 1 or 2"

LRV Class 1 (≥ 45) – "Can be used in 75-100% of surface to be /painted/coated"

LRV Class 2 (<45 or untested) – "Can be used in 0-25% of surface to be painted/coated provided the remaining area is Class 1".

Original Issue Date: 25 September 2018

Current Issue Date: 25 September 2018

Valid Until: 24 September 2019

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department