

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

ROOF PROOF INSULATION CONTRACTING L.L.C

Office No. 305, Al Zarooni Building, Damascus Street 334, Al Qusais, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



eiāci
مركز الاعتمادات العالمية للاعتماد
Emirates International Accreditation Centre
CB-003-PRD

Certificate No: CL19020673
Valid Until: 21/04/2020



Current Issue Date: 22/04/2019
Original Issue Date: 22/04/2019

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020673**

Certificate Issued To: **ROOF PROOF INSULATION CONTRACTING LLC**
Office No. 305, Al Zarooni Building, Damascus Street 334,
Al Qusais Area, Dubai, UAE

Applicable Standard Specification: BS EN 14315-1:2013 – Thermal insulating product for buildings –
In-situ formed sprayed rigid Polyurethane (PUR) and
Polyisocyanurate (PIR) foam products.

Applicable Specific Rules: DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of
In-Situ Spray applied Thermal Insulation as per BS EN 14315-1”.

S/N	Product Description	Brand Name	Product Details
1	In-Situ Formed Sprayed Polyurethane (PUR) Foam “CFC Free” **	ROOF PROOF	In-situ Formed Sprayed Polyurethane (PUR) Insulation Foam Thickness: 30 mm to 150 mm Core Density 40 kg/m ³ (min) Compressive Strength = 100 kPa (min) Dimensional stability DS (TH)2 Water Vapor Transmission = 25 (min) Water absorptions = 0.20 kg/m ² (max) Thermal Conductivity (max) – Initial Value: 0.028 W/(m.K); @ 35 °C & 60% RH* Code: PU EN14315-1-DS(TH)2- CS (10/Y)100-MU25

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: * Maximum k-value measured at 35°C temperature and 60% relative humidity condition.

NOTE 3: ** CFC Free as per declaration from the company, in accordance with the Al SA”FAT - Dubai Green Building Evaluation Systems.

Original Issue Date : 22 April 2019

Current Issue Date : 22 April 2019

Valid Until : 21 April 2020

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department