

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

SIRCA S.P.A.

Viale Roma 85, Massantago (PD), Italy

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



eiaci
مركز الاعتمادات العالمية للاعتماد
Emirates International Accreditation Centre
CB-003-PRD

Certificate No: CL19020675
Valid Until: 06/05/2020



Current Issue Date: 07/05/2019
Original Issue Date: 07/05/2019

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020675**

Certificate Issued To **SIRCA SPA**
Viale Roma 85, Massantago (PD), Italy

Applicable Standard Specification: 2017 Al Sa'fat Dubai Green Building Evaluation System

Applicable Specific Rules: RD-DP21-2180-(IC) Specific Rules for FA Certification of Low Emitting Materials as per Al Sa'fat – Dubai Green Building Evaluation System

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Interior/Exterior Trim Varnishes & Woodstains, including opaque woodstains	HoneyWB EXT Matt Topcoat OWE500G30-60	Water Base Paint for Interior/Exterior Application VOC (max. 130 g/l) Heavy metals: Cadmium and Chromium (< 500 mg/Kg), Arsenic, Mercury and Lead (<100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		Honey WB EXT Topcoat – OWE500G20	
		Clear WB EXT Sealer – FWE600	
2	Interior / Exterior Minimal Woodstains	WB For Broadleaves Impregnating Agent: Colourless - IMW4400	Water Base Paint for Exterior Application VOC (max. 130 g/l) Heavy metals: Cadmium and Chromium (< 500 mg/Kg), Arsenic, Mercury and Lead (<100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		Teak – IMW4411	
		Walnut – IMW4413	
		Oak – IMW4415	
		Light Mahogany – IMW4416	
		White – IMW4418	
		Larch – IMW4420	
		Mahogany – IMW4421	
		Green – IMW4423	
		Douglas – IMW4424	
		Brenner Walnut – IMW4425	
		Warm Walnut – IMW4451	
		Dark Wallnut – IMW4452	
Ebony – IMW4454			
Chestnut – IMW4466			
		Clear WB TX INT Sealer – FW004TIX	Water Base for Interior



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020675**

3	One Pack Performance Coating	White WB INT Sealer – FWPI130	Application VOC (max. 140 g/l) Heavy metals: Cadmium and Chromium (< 500 mg/Kg), Arsenic, Mercury and Lead (<100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		Clear WB for Flooring Matt Topcoat OW1FG10-60	
		WB INT Self Sealer – OW20	
		Clear WB Self Sealer OW108G5-70	
4	Two Pack Reactive Performance Coating for Specific End such as floor	White PU SB Sealer – FPP021LV	Solvent Base for Interior Application VOC (max. 500 g/l) Heavy metals: Cadmium and Chromium (< 500 mg/Kg), Arsenic, Mercury and Lead (<100 mg/Kg)
		Clear PU SB Sealer – FPU160LV	
		PU Hardener – CT7	
		PU Hardener – CTH25	
		Matt PU SB White - OPP530LV00G10-50 Yellow – OPP532LV00G10-50 Orange - OPP535LV00G10-50 Brown – OPP536LV00G10-50 Blue – OPP539LV00G10-50 Black – OPP540LV00G10-50 Red - OPP542LV00G10-50 Green – OPP543LV00G10-50 Violet – OPP548LV00G10-50 Ivory - OPP559LV00G10-50	
		Clear Matt PU Topcoat SB OPU160LVG10-50	

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above products shall bear the DCL Conformity Mark.

Original Issue Date: 07 May 2019

Current Issue Date: 07 May 2019

Valid Until: 06 May 2020

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department