

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Spray-Applied Cellular PUR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

AL MAYAS INSULATION CONT.

Industrial Area No. 12, GECO Complex, P.O. Box 27734, Sharjah, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C1029 - 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL13020195
Valid Until: 17/08/2021



Current Issue Date: 18/08/2020
Original Issue Date: 18/08/2013



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL13020195

Certificate Issued To: AL MAYAS INSULATION CONT.
Industrial Area No. 12, GECO Complex, PO Box 27734,
Sharjah, UAE

Applicable Standard Specification: ASTM C 1029-13 – Standard Specification for Spray-Applied Rigid Cellular Polyurethane Thermal Insulation

Applicable Specific Rules: DM-DCLD-RD-DP21-2112 (IC) “Specific Rules for Certification of Spray-Applied Rigid Cellular Polyurethane (PUR) Thermal Insulation (as per ASTM C 1029-13) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Spray-Applied Rigid Polyurethane Thermal Insulation CFC Free (see Note 3)	AL MAYAS	Type I Classification Density of 35 kg/m ³ (minimum) Nominal Thickness = 50 mm k-value: 0.0242 W/(K·m) (see Note 2) Compressive Strength of 104 kPa (minimum)

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: Maximum k-value measured at 35°C temperature and 60% relative humidity condition.

NOTE 3: CFC Free as per declaration from the company, in compliance with Clause 701.01 (1) of the 2017 Al Sa'fat Dubai Green Building Evaluation System..

Original Issue Date : 18 August 2013

Current Issue Date : 18 August 2020

Valid Until : 17 August 2021



ARIF HUSAIN AL MARZOOQI
Products Conformity Assessment Section Manager
Dubai Central Laboratory Department