

# CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality  
hereby attests that the product(s)

## Spray-Applied Cellular PUR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

**DESERT ROOFING & FLOORING LLC**

**Ras Al Khor Industrial Area, P.O. Box 185, Dubai, UAE**

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

## ASTM C1029 - 2015

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN  
Director, Dubai Central Laboratory Department  
Dubai Municipality



Certificate No: CL13020198  
Valid Until: 25/06/2021



Current Issue Date: 26/06/2020  
Original Issue Date: 13/11/2013



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.  
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL13020198**

<b>Certificate Issued To:</b>	<b>DESERT ROOFING &amp; FLOORING LLC</b> Ras Al Khor Industrial Area, P.O. Box 185, Dubai, UAE
<b>Applicable Standard Specification:</b>	ASTM C 1029:15 – Standard Specification for Spray Applied Rigid Cellular Polyurethane Thermal Insulation Foam
<b>Applicable Specific Rules:</b>	DM-DCLD-RD-DP21-2112 (IC) “Specific Rules for Certification of Spray-Applied Rigid Cellular Polyurethane (PUR) Thermal Insulation (as per ASTM C 1029-15) Through Factory Assessment”.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Spray-Applied Rigid Polyurethane Thermal Insulation <i>(see Note 3)</i>	DESERT ROOFING	Min. Density : 40 kg/m <sup>3</sup> Nominal Thickness = 50 mm k-value: 0.0242 W/(K.m) With a minimum Compressive Strength of 104 kPa

**NOTE 1:** This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

**NOTE 2:** The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).

**NOTE 3:** CFC Free as per declaration from the company, in compliance with 2017 Al Sa'fat Dubai Green Building Evaluation System.



---

**DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL13020198**

*Original Issue Date* : 13 November 2013

*Current Issue Date* : 26 June 2020

*Valid Until* : 25 June 2021

ARIF HUSAIN AL MARZOOQI  
Products Conformity Assessment Section Manager  
Dubai Central Laboratory Department