

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Spray-Applied Cellular PUR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:


AL SINDBAD INSULATION MAT. FIX.

Industrial Oasis, Al Saja'a, Sharjah, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

ASTM C1029 - 2015

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL15020276
Valid Until: 28/10/2021



Current Issue Date: 29/10/2020
Original Issue Date: 29/10/2015



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL15020276

Certificate Issued To:	AL SINDBAD INSULATION MAT. FIX Industrial Oasis, Al Saja'a, Sharjah, UAE
Applicable Standard Specification:	ASTM C1029-13 – Standard Specification for Spray-Applied Rigid Cellular Polyurethane Thermal Insulation
Applicable Specific Rules:	DM-DCLD-RD-DP21-2112 (IC) - Specific Rules for Certification of Spray-Applied Thermal Insulation as per ASTM C 1029

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Spray-Applied Rigid Polyurethane (PUR) Thermal Insulation CFC Free (see note 3)	AL SINDBAD	Type I Classification Min. Density : 40 kg/m ³ Ave. Thickness = 50 mm k-value: 0.0242 W/(K·m) (see note 2) With a minimum Compressive Strength of 104 kPa

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: Maximum k-value measured at 35°C temperature and 60% relative humidity conditions.

NOTE 3: CFC Free as per declaration from the company, in compliance with 2017 Al Sa'fat Dubai Green Building Evaluation System.

Original Issue Date : 29 October 2015

Current Issue Date : 29 October 2020

Valid Until : 28 October 2021

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department