

# CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality  
hereby attests that the product(s)

## In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:


**ISAM KABBANI & PARTNERS FOR CONSTRUCTION & MAINTENANCE LLC**

**Saih Suhaib 3, 4th R/A, PO Box: 282751, Dubai, UAE.**

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

## BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN  
Director, Dubai Central Laboratory Department  
Dubai Municipality



Certificate No: CL17020429  
Valid Until: 18/02/2022



Current Issue Date: 19/02/2021  
Original Issue Date: 19/02/2017



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.  
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL17020429

<b>Certificate Issued To:</b>	ISAM KABBANI & PARTNERS FOR CONSTRUCTION & MAINTENANCE LLC Saih Suhaib 3, 4th R/A, PO Box: 282751, Dubai, UAE
<b>Applicable Standard Specification:</b>	EN 14315-1:2013 – Thermal insulating products for buildings – In situ formed sprayed polyurethane (PUR) and Polyisocyanurate (PIR) foam products
<b>Applicable Specific Rules:</b>	DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of In Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per BS EN14315-1:2013) Through Factory Assessment”.

PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
In-Situ Formed Sprayed Polyurethane (PUR) Foam Products  CFC Free **	ISAM KABBANI	In Situ Formed Sprayed (PUR) Insulation Foam Thickness – 30mm to 150mm; Apparent Density - 40 kg/m <sup>3</sup> (min); Thermal conductivity (max) aged value - 0.028W/(m*K) @ 35 °C & 60% RH Minimum Compressive strength of 100 KPa Dimensional Stability DS(TH)2 Min. Water Vapor transmission factor, MU: 25 Code: PU EN 14315-1 - CS(10/Y)100 - DS(TH) 2 – MU25

**NOTE 1:** This document forms part of the Certificate of Product Conformity bearing the same certificate number.



DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION**  
**FOR CERTIFICATE NO. CL17020429**

*NOTE 2: \*CFC Free as per declaration from the company in accordance with the 2017 Al Sa'fat – Dubai Green Building Evaluation System*

*Original Issue Date: 19 February 2017*

*Current Issue Date: 19 February 2021*

*Valid Until: 18 February 2022*

ARIF HUSAIN AL MARZOOQI  
Products Conformity Assessment Section Manager  
Dubai Central Laboratory Department