



CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

HEPTA WATER PROOFING AND THERMAL INSULATION LLC P.O. Box 34494, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer to affix the DCL Product Conformity Mark on the above-mentioned product(s).

> for / ENGR. AMIN AHMED AMIN Director, Dubai Central Laboratory Department **Dubai Municipality**



Certificate No: CL17020451 Valid Until: 02/05/2021



Current Issue Date: 03/05/2020 Original Issue Date: 03/05/2017



DM-DCLD-F-IC-2031 Rev 17

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate. This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.











DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL17020451

Certificate Issued To: HEPTA WATER PROOFING AND THERMAL INSULATION LLC

P.O. Box 34494, Dubai, UAE

Applicable Standard Specification: BS EN 14315-1:2013 – Thermal Insulating Product for Buildings

In-situ Formed Sprayed Rigid Polyurethane (PUR) and PIR Foam

Products

Applicable Specific Rules: DM-DCLD-RD-DP21-2187 (IC) "Specific Rules for Certification of

In-Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam

Products (as per EN14315-1:2013) Through Factory

Assessment".

S/N	Product Description	Brand Name	Product Details
1	In Situ-Formed Sprayed Polyurethane (PUR) Foam Products "CFC Free" **	НЕРТА	In-Situ Formed Sprayed Polyurethane (PUR) Foam Min. Density: 40 kg/m³ Min. Thickness = 30 mm k-value: 0.026 W/(K•m)* With a minimum Compressive Strength of 100 kPa Product Code: PU EN14315-1-DS(TH)2-CS(10/Y)100-MU(25)

NOTE 1: * Maximum k-value measured at 35:C temperature and 60% relative humidity condition.

NOTE 2: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 3: ** CFC Free as per declaration from the company, in accordance with the 2017 Al Safat Dubai Green Building Evaluation System.

Original Issue Date: 03 MAY 2017

Current Issue Date: 03 MAY 2020

Valid Until : 02 MAY 2021

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager

Dubai Central Laboratory Department