

# CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality  
hereby attests that the product(s)

## In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

**AL KHUMASIYYA CONSTRUCTIONS & INSULATION MATERIALS**

**P.O. Box 73729, Abu Dhabi, U.A.E.**

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

## BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN  
Director, Dubai Central Laboratory Department  
Dubai Municipality



001-CB-PRD

Certificate No: CL17020471  
Valid Until: 03/07/2021



Current Issue Date: 04/07/2020  
Original Issue Date: 04/07/2017



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.  
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL17020471

<b>Certificate Issued To:</b>	AL KHUMASIYYA CONSTRUCTIONS & INSULATION MATERIALS P.O. Box 73729, Abu Dhabi, U.A.E.
<b>Applicable Standard Specification:</b>	BS EN 14315-1:2013 – Thermal Insulating Product for Buildings In-situ Formed Sprayed Rigid Polyurethane (PUR) and PIR Foam Products
<b>Applicable Specific Rules:</b>	DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of In-Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per EN14315-1:2013) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Spray-Applied Rigid Polyurethane (PUR) Foam Products  “CFC Free” **	KUMAT COMBO	Core Density : 40 kg/m <sup>3</sup>  Min. Thickness = 35 mm  Thermal Conductivity: 0.029 W/(K·m)* (max)  With a minimum Compressive Strength of 100 kPa  Dimensional Stability DS(TH)2  Product Code:  PU EN14315-1-DS(TH)2-CS(10/Y)100-MU(25)

NOTE1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: \* Maximum k-value measured at 35°C temperature and 60% relative humidity Condition.

NOTE3: \*\* CFC Free as per declaration from the company in accordance with the 2017 Al Sa'fat – Dubai Green Building

Evaluation System

Original Issue Date : 04 July 2017

Current Issue Date : 04 July 2020

Valid Until : 03 July 2021



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager  
Dubai Central Laboratory Department