

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

QUALITY HOUSE INSULATION, PLASTER & TILES CONT. LLC

P.O. Box 72350, Sharjah, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL17020506
Valid Until: 10/10/2021



Current Issue Date: 11/10/2020
Original Issue Date: 24/09/2017



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL17020506

Certificate Issued To:	QUALITY HOUSE INSULATION PLASTER & TILES CONT. LLC P.O. Box 72350, Sharjah, UAE
Applicable Standard Specification:	BS EN 14315-1:2013 – Thermal Insulating Product for Buildings In-situ Formed Sprayed Rigid Polyurethane (PUR) and PIR Foam Products
Applicable Specific Rules:	DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of In-Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per EN14315-1:2013) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Spray-Applied Rigid Polyurethane Thermal Insulation Foam CFC Free (see Note 3)	COMBO ROOF PLUS	In Situ Formed Sprayed PUR Insulation Foam Core Density = 38 kg/m ³ Thickness (min) = 45mm *Thermal Cond. (max) value - 0.030 W/(m*K) @ 35 °C & 60% RH Minimum Compressive strength of 100 KPa Dimensional Stability DS(TH)2 Min. Water Vapor transmission factor, MU = 100 CODE : PU-EN 14315 -1-DS(TH)2 – CS(10/Y) 100 - MU100

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: Maximum k-value measured at 35°C temperature and 60% relative humidity condition.

NOTE 3: CFC Free as per declaration from the company, in compliance with Clause 701.01 (1) of the 2017 Al Sa'fat Dubai
Green Building Evaluation System..

Original Issue Date : 24 September 2017

Current Issue Date : 11 October 2020

Valid Until : 10 October 2021



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department