

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

ROOFTEK INSULATION CONTRACTING LLC

Level 1, #1014, Waha Community Building, P.O. Box 48289, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL18020650
Valid Until: 22/12/2020



Current Issue Date: 23/12/2019
Original Issue Date: 23/12/2018

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL18020650

Certificate Issued To:	ROOFTEK INSULATION CONTRACTING LLC Level 1, #1014, Waha Community Building, P.O. Box 48289, Dubai, UAE
Applicable Standard Specification:	EN 14315-1:2013 – Thermal Insulating Product for Buildings In-situ Formed Sprayed Rigid Polyurethane (PUR) and PIR Foam Products
Applicable Specific Rules:	DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of In-Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per EN14315-1:2013) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Spray-Applied Rigid Polyurethane (PUR) Foam Products <i>“CFC Free” *</i>	ROOFTEK	Min. Density : 38 kg/m ³ Thickness: 35-150 mm k-value: 0.029 W/K•m (max @ 35°C & 60% RH) With a min. Compressive Strength of 100 kPa Dimensional Stability (DS(TH)2 Short term water absorption by partial immersion: 0.1 kg/m ² (max) Product Code: PU EN14315-1-DS(TH)2-CS(10/Y)100-MU(25)

NOTE1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: The above product shall bear the DCL Conformity Mark.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020650**

*NOTE 3: *CFC Free as per declaration from the company in accordance with the 2017 Al Sa'fat – Dubai Green Building Evaluation System*

Original Issue Date : 23 December 2018

Current Issue Date : 23 December 2019

Valid Until : 22 December 2020

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department