

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

AL GURG FOSROC LLC

Umm Ramool Industrial Area, Rashidiya, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL17020444
Valid Until: 11/06/2021



Current Issue Date: 12/06/2020
Original Issue Date: 12/06/2017



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL17020444

Certificate Issued To

AL GURG FOSROC L.L.C

Umm Ramool Industrial Area, Rashidiya, Dubai, UAE

Applicable Standard Specification:

2017 Al Sa'fat Dubai Green Building Evaluation System

Applicable Specific Rules:

DM-DCLD-RD-DP21-2180-(IC) Specific Rules for Certification of Low Emitting Materials (Coatings, Adhesives & Sealants) As per the 2017 Al Sa'fat Dubai Green Building Evaluation System.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	CATEGORY 8 Binding Primers	Nitoprime WB *	Water Base for Interior and Exterior Application VOC (Al Sa'fat DGBES limit is max.750g/l)
		Dekguard Primer WB *	
		Dekguard EP302 *	
		Proofex Tackcoat WB	
		Nitocote SN502 *	Solvent Base for Interior and Exterior Application VOC (Al Sa'fat DGBES limit is max.750g/l) Heavy metals: Cadmium and Chromium (Al Sa'fat DGBES limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat DGBES limit <100 mg/Kg)
		Nitocote SN522 *	
		Nitocote Primer Sealer *	
		Nitoprime SP *	
		Nitoprime Zincrich *	
		Nitoprime 25 *	
		Nitoprime 31 *	
		Nitoseal Primer MS2 *	
		Dekguard Primer *	
		Dekguard Primer DG *	
		Trafficguard Primer *	
		Primer 7E *	
		Galvafruid *	
		Proofex Tackcoat	
		Proofex Torchseal Primer	
2	CATEGORY 9 One Pack Performance Coating	Dekguard E2000 *	Water Base for Interior and/or Exterior Application VOC (Al Sa'fat DGBES limit is max.140 g/l) WHITE COLOR Class 1: SRI is ≥78 (suitable for steep sloped surface and for flat or low sloped surface)
		Dekguard AC *	
		Dekguard PU 100 *	
		Dekguard Filler *	
		Nitocote PE135 *	
		Nitocote HEX *	
		Nitoproof 600 WB *	
		Nitoproof 10	

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL17020444

		Nitoproof 30	Class 1: LRV is $\geq 45\%$ (suitable as exterior coating for building) (SEE NOTE 3)
		Nitoproof 110	
		Nitoproof 120	
		Nitoproof 230	
		Nitoflor Lithurin 2	
		Nitoflor Hardtop	
		Nitoflor Levelcrete	
		Nitoflor Emeritop	
		Nitoproof 100	
		Nitoproof 600	
		Cemtop 200	
		Cemtop 250T	
		Cemtop 400 SD	
		Cemtop HD	
		Brushbond TGP	
		Nitoflor FC 100 *	Solvent Base for Interior and/or Exterior Application VOC (Al Sa'fat DGBES limit is max.500 g/l)
		Dekguard S *	
3	CATEGORY 10 Two Pack Reactive Performance Coating	Nitoflor FC130 *	Water Base for Interior and Exterior Application VOC (Al Sa'fat DGBES limit is max.140 g/l) WHITE COLOR Class 1 : SRI is ≥ 78 (suitable for steep sloped surface and for flat or low sloped surface) Class 1 : LRV is $\geq 45\%$ (suitable as exterior coating for buildings) (SEE NOTE 3)
		Nitoflor FC550 *	
		Nitoflor Conductive Undercoat *	
		Nitocote CM210	
		Brushbond	
		Brushbond FLXIII	Solvent Base for Interior and Exterior Application VOC (Al Sa'fat DGBES limit is max.500 g/l) WHITE COLOR Class 1 : SRI is ≥ 78 (suitable for steep sloped surface and for flat or low sloped surface) Class 1 : LRV is $\geq 45\%$ (suitable as exterior coating for buildings) (SEE NOTE 3)
		Dekguard PU *	
		Nitocote EPS *	
		Nitocote EPU *	
		Nitoflor EPU 100 *	
		Nitocote EP403 *	
		Nitocote EP405 *	
		Nitocote EP410 *	
		Nitocote ET402 *	
		Nitocote ET402-E *	
		Nitocote ET550 *	
		Nitocote EN901 *	

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL17020444

		Nitocote NT402 *	<p>Solvent Base for Interior and Exterior Application</p> <p>VOC (Al Sa'fat DGBES limit is max.500 g/l)</p> <p>WHITE COLOR</p> <p>Class 1 : SRI is ≥ 78 (suitable for steep sloped surface and for flat or low sloped surface)</p> <p>Class 1 : LRV is $\geq 45\%$ (suitable as exterior coating for buildings)</p> <p>(SEE NOTE 3)</p>
		Nitocote NT550 *	
		Nitocote HT120 *	
		Nitoflor Conductive *	
		Nitoflor EU5 *	
		Nitoflor EU10 *	
		Nitoflor EU50 *	
		Nitoflor FC140 *	
		Nitoflor FC145 *	
		Nitoflor FC150 *	
		Nitoflor FC400 UH *	
		Nitoflor SL1000 *	
		Nitoflor SL2000 *	
		Nitoflor SL3000 *	
		Nitoflor SL4000 *	
		Nitoflor SL6000 UB *	
		Nitoflor TF100 UH *	
		Nitoflor TF120 UB *	
		Nitoflor TF5000 *	
		Nitoflor ET Slurry *	
		Trafficguard Top Coat *	
		Trafficguard Wear Course *	
		Trafficguard Membrane *	
		Trafficguard Intermediate *	
4	Sealants	Polyurea WPE	<p>Architectural Application</p> <p>VOC (Al Sa'fat DGBES limit is max.250 g/l)</p>
		Polyurea FLM	
		Nitoseal PE290 *	
		Nitoseal PU280 *	
		Colpor 200	
		Flamex I	
		Flamex II	
		Nitoseal MS60	
		Nitoseal MS100	
		Nitoseal MS300	
		Nitoseal MS600	
		Nitoseal PU40	
		Nitoseal PU220	
		Nitoseal PU220-PF	
		Thioflex 600	

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION FOR CERTIFICATE NO. CL17020444

5	Adhesives	Nitobond EP *	Multi-Purpose Construction Adhesive VOC (Al Sa'fat DGBES limit is max.70 g/l)
		Nitobond SBR	
		Nitobond AR	
		Nitotile 489 *	
		Nitobond Tile Adhesive	Ceramic Tile Adhesive VOC (Al Sa'fat DGBES limit is max. 65 g/l)
		Nitotile GP	
		Nitotile LM	
		Nitotile EN	
		Nitotile C1Fix	
		Nitotile C2 Highfix	
		Nitotile XS	

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above products shall bear the DCL Conformity Mark.

NOTE 3: For colors/types not covered by the Scope, SRI and LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of the DM-GBRS.

- SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”
- SRI Class 2 ($29 < 78$) - “Can be Used in 75 - 100% of surface to be coated – Sloped Roof”
- SRI Class 3 (< 29 or untested) – “Can be Used in 0 – 25% of surface to be coated – Sloped or Flat Roof provided the remaining area is Class 1 or 2”
- LRV Class 1 (≥ 45) – “Can be used in 75-100% of surface to be /painted/coated”
- LRV Class 2 (< 45 or untested) – “Can be used in 0-25% of surface to be painted/coated provided the remaining area is Class 1”.

NOTE 4: “ * ” – The Products are produced in **AL GURG FOSROC L.L.C BRANCH**, Industrial Area1, Jabel Ali, Dubai, UAE.

Original Issue Date: 12 June 2017

Current Issue Date: 12 June 2020

Valid Until: 11 June 2021



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department