

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

CAPAROL PAINTS LLC

Saih Shuaib-4 Dubai Industrial City, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



001-CB-PRD

Certificate No: CL17020465
Valid Until: 06/06/2021



Current Issue Date: 07/06/2020
Original Issue Date: 07/06/2017



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION Rev 01
FOR CERTIFICATE NO. CL17020465

Certificate Issued To

CAPAROL PAINTS LLC

Saih Shuaib-4, Dubai Industrial City, Dubai, UAE

Applicable Standard Specification:

2017 Al Sa'fat - Dubai Green Building Evaluation
System

Applicable Specific Rules:

DM-DCLD-RD-DP21-2180 (IC) Specific Rules for
FA Certification of Low Emitting Materials as per
2017 Al Sa'fat - Dubai Green Building Evaluation
System

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Interior Matt Walls and Ceilings Paint (Gloss < 25 @ 60°) (sub category 1)	AirPurify	Water Base Paint for Interior Application Only: VOC (Al Sa'fat-DGBES limit is max.30 g/l) Heavy metals: Cadmium and Chromium VI (Al Sa'fat-DGBES limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat-DGBES limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		CapaCare	
		CapaMat	
		CapaPlus	
		CleanStar	
		CapaFlat	
		Optima Interior *	
2	Interior glossy walls and ceilings paints (Gloss > 25 @60°) (sub category 2)	CleanStar	Water Base Paint for Interior Application Only: VOC (Al Sa'fat-DGBES limit is max.100 g/l) Heavy metals: Cadmium and Chromium VI (Al Sa'fat-DGBES limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat-DGBES limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		Amphibolin	

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION Rev 01
FOR CERTIFICATE NO. CL17020465

3	Primers (sub category 7)	CapaPutz Primer	Water based Primer for Interior/Exterior Applications: VOC (Al Sa'fat-DGBES limit is max.30 g/l) Heavy metals: Cadmium & Chromium VI (Al Sa'fat-DGBES limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat-DGBES limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		CapaStucco	
		FlexoPrime	
		StonePrime	
		CapaAcryl Primer	
		CapaFilex	
		CapaPrime	
4	Decorative Effects Coatings (sub category 12)	Metallocryl Interior	Water Base Paint for Interior Application Only: VOC (Al Sa'fat-DGBES limit is max 200 g/l) Heavy metals: Cadmium & Chromium VI (Al Sa'fat-DGBES limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat-DGBES limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg
		Makhmalia	
5	Exterior Walls of Mineral Substrate (sub category 3)	FlexoTop	Water Base Paint for Exterior Application: VOC (Al Sa'fat-DGBES limit is max 40 g/l) Heavy metals: Cadmium & Chromium VI (Al Sa'fat-DGBES limit < 500 mg/Kg), Arsenic, Mercury and Lead (Al Sa'fat-DGBES limit <100 mg/Kg) Formaldehyde ≤ 10 mg/kg LRV Class: Class 1 (see Note 3)
		Amphibolin	
		CapaUltra Matt	
		CleanStar	
		CapaShield	
		CapaTex (Textured coatings)	
		TopTex (Textured coatings)	
		CapaGrain (Textured coatings)	
		CapaStructure (Textured coatings)	
		FlexoGuard	
		StructurePutz (Textured coatings)	
		FlexoShield	
		CapaSpraYtex (Textured coatings)	
		FlexoPutz	

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION Rev 01 FOR CERTIFICATE NO. CL17020465

		Flexotex	
		CapaStone NanoClear	
		Ceratile	
		Ceratone	
		Granito	
		Eurostone	
		CapaStone Basecoat	
		Decocoat	
		Optima Exterior *	
		Capacoat Exterior *	
		Nano 360 *	
6	One -pack Performance Coatings (sub category 9)	Capalac Enamel	Solvent Base Coating for Interior/Exterior Applications: VOC (Al Sa'fat-DGBES limit is max 500 g/l) LRV Class: Class 2 (see Note 3) (Average LRV Class 2 < 45)
		CapaTopacryl	
		CapaMark	LRV Class: Class 1 (see Note 3) (Average LRV Class 1 ≥ 45)
7	Two -pack Reactive Performance Coatings for specific end use such as floors (sub category 10)	CapaEpoTop	Solvent Base/Solvent Free Coating for Exterior/Interior Application: VOC (Al Sa'fat-DGBES limit is max 500 g/l) LRV Class: Class 1 (see Note 3) (Average LRV Class 1 ≥ 45)
		CapaEpoTex	
		CapaThane	
		CapaEpo HB undercoat	
		DisboPOX 110 SB	
		DisboPOX 210 SF	
		DisboPOX 230 SF	
		DisboPUR 630 PU	
		DisboPOX 231 SF *	
8	Binding Primers (sub category 8)	Capalac red oxide primer	Solvent Base Primer for Interior/Exterior Applications: VOC (Al Sa'fat-DGBES limit is max 750 g/l)
		Capalac Metal primer	
		CapaLac Primer / Wood Primer / Undercoat	

DUBAI CENTRAL LABORATORY DEPARTMENT DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION Rev 01 FOR CERTIFICATE NO. CL17020465

		Capaseal SB	
		Disboxan 485	

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCL Conformity Mark.

NOTE 3: For colors/types not covered by the Scope, LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of the DM-GBRS.

- LRV Class 1 (≥ 45) – “Can be used in 75-100% of surface to be /painted/coated”
- LRV Class 2 (< 45 or untested) – “Can be used in 0-25% of surface to be painted/coated provided the remaining area is Class 1”.

NOTE 4: “ * “ Additional New Products

NOTE 5: This supersedes the scope of certification issued on 07 June 2020

Original Issue Date: 07 June 2017

Current Issue Date: 22 November 2020

Valid Until: 06 June 2021



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager

Dubai Central Laboratory Department