

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:


SIKA MANUFACTURING AG

MURTENSTRASSE 19, 3186, DUDINGEN, SWITZERLAND

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL18020589
Valid Until: 03/06/2021



Current Issue Date: 04/06/2020
Original Issue Date: 04/06/2018



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

SCOPE OF CERTIFICATION

FOR CERTIFICATE NO. CL18020589

Certificate Issued To

SIKA MANUFACTURING AG

Murtenstrasse 19, 3186, Duding, Switzerland

Applicable Standard Specification:

2017 Al Sa'fat Dubai Green Building Evaluation System

Applicable Specific Rules:

DM-DCLD-RD-DP21-2180-(IC) Specific Rules for FA
Certification of Low Emitting Materials as per Al Sa'fat –
Dubai Green Building Evaluation System (DGBES)

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Adhesives, (Multipurpose Construction Adhesive)	Sikaflex® Construction+	VOC (Al Sa'fat DGBES limit is max 70 g/l)
		Sikaflex® PRO-3	
		Sikaflex® -11FC+	
		SikaBond®-115 Strong Fix	VOC (Al Sa'fat DGBES limit is max 70 g/l) SEE NOTE 3
		Sikaflex®-112 Crystal Clear	
2	Adhesives, (Wood Flooring Adhesive)	SikaBond® -52 Parquet	VOC (Al Sa'fat DGBES limit is max 100 g/l)
		SikaBond® -54 Parquet	
3	Sealants (Architectural Sealant)	Sikaflex® Precast	VOC (Al Sa'fat DGBES limit is max 250 g/l)
		1C PU Sealant	
		SikaHyflex® -250 Façade	

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020589**

	Sealants (Architectural Sealant)	Sikacryl®-100	VOC (Al Sa'fat DGBES limit is max 250 g/l) SEE NOTE 3
		Sikacryl®-150	
		Sikacryl®-200	
		SikaSeal®-106 Construction	
		Sikacryl®-620 Fire	
		SikaHyflex®-100	
		SikaHyflex®-105	
		SikaHyflex®-305 EU	
		Sikasil®-670 Fire	
4	Sealants (Other)	SikaBond®-114 Grip Tight	VOC (Al Sa'fat DGBES limit is max 420 g/l) SEE NOTE 3

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCL Conformity Mark.

NOTE 3: Produced by SIKA LIMITED - EVERBUILD BUILDING PRODUCTS LIMITED, an outsourced factory by SIKA MANUFACTURING AG .

Original Issue Date: 04 June 2018

Current Issue Date: 04 June 2020

Valid Until: 03 June 2021



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department