

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

GREEN IDEA TECHNICAL SERVICES LLC

Office No. 707, The Metropolis Tower, Business Bay, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL18020624
Valid Until: 13/08/2021



Current Issue Date: 14/08/2020
Original Issue Date: 14/08/2018



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020624**

Certificate Issued To:	GREEN IDEA TECHNICAL SERVICES LLC Office No. 707, The Metropolis Tower, Business Bay, Dubai, UAE
Applicable Standard Specification:	EN 14315-1:2013 – Thermal insulating products for buildings – In situ formed sprayed polyurethane (PUR) and Polyisocyanurate (PIR) foam products – Part 1: Specification for the rigid foam spray system before installation
Applicable Specific Rules:	DM-DCLD-RD-DP21-2187 (IC) - Specific Rule for Certification of In situ formed sprayed polyurethane (PUR) foam Thermal Insulation as per BS EN 14315-1: 2013

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	In-Situ Formed Sprayed Polyurethane (PUR) Foam Products CFC Free (see note 3)	GREEN IDEA COMBO ROOF WATER WATERPROOFING SYSTEM	In Situ Formed Sprayed PUR Insulation Foam Core Density (min) = 40 kg/m ³ Thickness (min) = 45mm Thermal Cond. (max) value - 0.0240 W/(m-K) @ 35 °C & 60% RH (see note 2) Minimum Compressive strength of 100 KPa Dimensional Stability DS(TH)2 Min. Water Vapor transmission factor, MU = 25 CODE : PU-EN 14315 -1-DS(TH)2 – CS(10/Y) 100 – MU25

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: Maximum k-value measured at 35°C temperature and 60% relative humidity conditions.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020624**

NOTE 3: CFC Free as per declaration from the company, in compliance with 2017 Al Sa'fat Dubai Green Building Evaluation System.

Original Issue Date : 14 August 2018

Current Issue Date : 14 August 2020

Valid Until : 13 August 2021

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department