

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

ANCHOR ALLIED FACTORY L.L.C. BRANCH 3
P.O. Box 21152, Emirates Industrial City, Sajjah, Sharjah, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL18020574
Valid Until: 14/04/2022



Current Issue Date: 15/04/2021
Original Issue Date: 15/04/2018



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020574**

Certificate Issued To: ANCHOR ALLIED FACTORY L.L.C. BRANCH 3
P.O. Box 21152, Emirates Industrial City, Sajjah, Sharjah, UAE

Applicable Standard Specification: 2017 Al Sa'fat – Dubai Green Building Evaluation System

Applicable Specific Rules: DM-DCLD-RD-DP21-2180-(IC) Specific Rules for FA Certification of Low Emitting Materials as per Al Sa'fat - Dubai Green Building Evaluation System.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
THE PRODUCTS PRODUCED IN "ANCHOR ALLIED FACTORY - LLC - BRANCH 3", SHARJAH.			
1	ARCHITECTURAL SEALANT	ASMACO GOLD UNIVERSAL MULTI FOAM B1 GRADE	Sealant for Specific Application VOC (Al Sa'fat DGBES limit is Max 250 g/l)
		ASMACO GOLD UNIVERSAL MULTI FOAM B2 GRADE	
		ASMACO GOLD UNIVERSAL MULTI FOAM	
		ASMACO UNIVERSAL MULTIFORM (NORMAL)	
THE PRODUCTS PRODUCED IN "ANCHOR ALLIED FACTORY - LLC", RAS AL KHAIMAH (External/Outsourced Production Facility)			
1	ONE PACK PERFORMANCE COATING (SUB-CATEGORY: 9)	ASMACOAT WP 900	Solvent Base Coatings for Interior/Exterior intermediate coatings Applications (Coating - Other Types) VOC (Al Sa'fat DGBES limit is Max.500 g/l) SRI Class 1 (≥ 78) – "Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof" (See Note 3)
		ASMACOAT WP 810	
		ASMACOAT WP 936	
		ASMACOAT WP 600 (White Color)	
2	ARCHITECTURAL SEALANT	ASMACO 2670	Sealant for Specific Application VOC (Al Sa'fat DGBES limit is Max 250 g/l)
		ASMACO GLASS	



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL18020574**

		<p>ASMACO FIRESTOP SILICONE SEALANT</p> <p>ASMACO INTUMESCENT ACRYLIC SEALANT</p> <p>ASMACO PU 90</p> <p>NEOFLEX PU 25LM</p> <p>ASMACRYL 47</p> <p>ASMACRYL 52</p> <p>GYPROC SEALANT</p> <p>CRAYCOAT ACRYLIC DUCT SEALANT</p> <p>"Asianpaints Berger" Brand SMARTCARE UNYVERSEAL NEUTRAL</p> <p>"Asianpaints Berger" Brand SMARTCARE ACRYLMAX</p> <p>"Asianpaints Berger" Brand SMARTCARE UNYVERSEAL PU</p> <p>"Asianpaints Berger" Brand SMARTCARE UNYVERSEAL POLYSULPHIDE PG</p> <p>"Asianpaints Berger" Brand SMARTCARE UNYVERSEAL POLYSULPHIDE GG</p> <p>ANCHORSEAL 963 PG</p> <p>ANCHORSEAL 963 GG</p>	
3	SEALANTS OTHER	<p>ASMACO 2500</p> <p>ASMACO GP</p> <p>ASMACO 2540</p> <p>"Asianpaints Berger" Brand SMARTCARE UNYVERSEAL ANTIFUNGAL</p> <p>"Asianpaints Berger" Brand SMARTCARE UNYVERSEAL GP ADVANCED</p>	<p>VOC (Al Sa'fat DGBES limit is Max 420 g/l)</p>
4	ADHESIVE-SPECIALTY APPLICATIONS	<p>ASMACO GOLD CONTACT ADHESIVE</p>	<p>(Sheet Applied Rubber Lining Operations) VOC (Al Sa'fat DGBES limit is Max 850 g/l)</p>

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

SCOPE OF CERTIFICATION

FOR CERTIFICATE NO. CL18020574

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCL Conformity Mark.

NOTE 3: For colors/types not covered by the Scope, SRI shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of the 2017 Al Sa'fat –Dubai Green Building Evaluation System.

- SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”
- SRI Class 2 ($29 < 78$) - “Can be Used in 75 - 100% of surface to be coated – Sloped Roof”
- SRI Class 3 (< 29 or untested) – “Can be Used in 0 – 25% of surface to be coated – Sloped or Flat Roof “

Original Issue Date: 15 April 2018

Current Issue Date: 15 April 2021

Valid Until: 14 April 2022

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager

Dubai Central Laboratory Department