

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

STAR ADHESIVE AND RESIN IND FACTORY

P. O. Box: 7558, NEW INDUSTRIAL AREA, UMM AL QUWAIN, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL19020670
Valid Until: 13/06/2020



Current Issue Date: 14/04/2020
Original Issue Date: 14/04/2019

The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME
SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020670

Certificate Issued To:

STAR ADHESIVE & RESIN IND FACTORY

P. O. Box: 7558, NEW INDUSTRIAL AREA, UMM ALQUWAIN,
UAE.

Applicable Standard Specification:

2017 Al Sa'fat – Dubai Green Building Evaluation System.

Applicable Specific Rules:

DM-DCLD-RD-DP21-2180-(IC) Specific Rules for FA
Certification of Low Emitting Materials as per Al Sa'fat - Dubai
Green Building Evaluation System.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	ONE PACK PERFORMANCE COATING (SUB-CATEGORY: 9)	Starfix DC 30-60	Water Base Coatings for Interior coatings Applications (Coating - Other Types) VOC (Al Sa'fat DGBES limit is Max.140 g/l)
		Starbond UL 30-36	
		Starfix 30-36	
		EMD Coat 30-36	
		Starfix AF 30-36	
		Starfix VB-95	
		Rockfix 30-36	
		Starproof WF AB-602	
		Starproof 605	
		Gmark 30-36-0	
		Starproof WF AC-600	Water Base Coatings for Interior/Exterior applications (Roof Coating). (White Color) VOC (Al Sa'fat DGBES limit is max.140g/l) SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”
		Starproof WF AC-603	
		Starproof 5000	
		Starproof HR-900	
2	ADHESIVE - SUBSTRATE SPECIFIC APPLICATIONS	Starfix GP-50	Wood Adhesive VOC (Al Sa'fat DGBES limit is Max 30 g/l)
		Starfix HP-20	
3	ADHESIVE - SPECIALTY APPLICATIONS	Starfix CW	Contact Adhesive VOC (Al Sa'fat DGBES limit is Max 80g/l)
		Strafix LV CW	
		Starfix VLV CW	
		Starfix CW-R	
		Starfix MP-500	
		Starfix XP-350	
		Starfix CA 22-10	Sheet Applied Rubber Lining Operations VOC (Al Sa'fat DGBES limit is Max 850 g/l)
		Starfix DG 81-10	
		Starfix 81-10	
		Starbond UL 81-10	
		Starfix R-242	
		Starfix NG 81-10	
		Starfix DG PH-24	
		Starbond FX	
		Starbond 85-60	
		Starfix CRP-15	
		Starbond CA 22-11	
		Starfix CA 22-13	
		Starfix CA 22-15	
		Starbond CA-50	
		Gmark 81-10-0	
		Gmark CA 22-10	



DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME
SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020670

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE 2: The above product shall bear the DCL Conformity Mark.

NOTE 3: For colors/types not covered by the Scope, SRI/LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of the 2017 Al Sa'fat –Dubai Green Building Evaluation System.

SRI Class 1 (≥ 78) – “Can be Used in 75 - 100% of surface to be coated – Sloped or Flat Roof”

SRI Class 2 ($29 < 78$) - “Can be Used in 75 - 100% of surface to be coated – Sloped Roof”

SRI Class 3 (< 29 or untested) – “Can be Used in 0 – 25% of surface to be coated – Sloped or Flat Roof “

LRV Class 1 (≥ 45) – “Can be used in 75-100% of surface to be /painted/coated”

LRV Class 2 (< 45) – “Can be used in 0-25% of surface to be painted/coated”

NOTE 4: This certificate is extended for two months based on the guidelines of DM-DCLD-RD-DP21-2007 (IC) Special Rules - Guideline for Extraordinary Events (COVID19).

Original Issue Date: 14-April-2019

Current Issue Date: 14-April-2020

Valid Until: 13-June-2020

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department