

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Low Emitting Materials

(Details as per the attached Scope of Certification)

manufactured by:

CORROTECH CONSTRUCTION CHEMICALS- CC1

Dubai Investment Park 1, Jebel Ali, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL19020686
Valid Until: 24/06/2021



Current Issue Date: 25/06/2020
Original Issue Date: 25/06/2019



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.



DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020686

Certificate Issued To:

CORROTECH CONSTRUCTION CHEMICALS-CC1

Dubai Investment Park 1, Jebel Ali, Dubai, UAE

Applicable Standard Specification:

2017 Al Sa'fat Dubai Green Building Evaluation System.

Applicable Specific Rules:

DM.DCLD-RD-DP21-2180-(IC) Specific Rules for Certification Low Emitting Materials (Paints, Coatings, Adhesives, Sealants) As per the 2017 Al Sa'fat Dubai Green Building Evaluation System (DGBES).

S/N	Product Description	Brand Name	Product Details
1	One Pack Performance Coating (Category 9 -Table A.1)	Corrocure AR Corrocure WXB Corrorelease WB Corrotard CSR Corrocoat OWR Corroflex Corrofloor FH Corrocoat AC	Water Base Coating for Interior coatings products VOC (Al Sa'fat-DGBES Limit is max.140 g/l) LRV Class 1 (≥45) – “Can be used in 75-100% of surface to be coated” (SEE NOTE 3)
2	One Pack performance coating (category 9-Table A.1)	Corrorelease OB Corrocoat WR UV Sealer UV Lacquer	Solvent Base Coating for Interior & Exterior coatings products VOC (Al Sa'fat-DGBES Limit is max.500 g/l) LRV Class 1 (≥45) – “Can be used in 75-100% of surface to be coated” (SEE NOTE 3)
3	Two Pack reactive Performance Coating (Category 10 - Table A.1)	Corrofloor 327 CorrofloorSF 500 Corrofloor SF400 Corrocoat EPS Corrofill EP Corrofill PU Corrofill WS Corrogrout EPLEM Corrogrout AG Corroprufe FCW	Water Base Coating for Interior coatings products VOC (Al Sa'fat-DGBES Limit is max.140 g/l) LRV Class 1 (≥45) – “Can be used in 75-100% of surface to be coated” (SEE NOTE 3)



**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020686**

4	Binding Primers (Category 8 - Table A.1)	Corrobond SBR Corrobond PVA Corrobond AR Corrobond EBA	Water Base Binding primer for Interior coatings products VOC (Al Sa'fat-DGBES Limit is max.30 g/l)
5	Primers (Category 8 - Table A.1)	Corroprime EPSF Corroprime AC	Water Base primer for Interior coatings products VOC (Al Sa'fat-DGBES Limit is max.30 g/l)
		Corroprime 30S Corroprime 626 Corroprime ZR1	Solvent Base primer for Interior coatings products VOC (Al Sa'fat-DGBES Limit is max.30 g/l)
6	Sealant (Other)	Coroseal PS 749 PG / GG	VOC (Al Sa'fat-DGBES Limit is max.420 g/l)
7	Adhesives (Architectural Applications)	Corrobond ETA Corrobond CTA Corrobond FTA Corrobond WTA	Ceramic Tile Adhesive VOC (Al Sa'fat-DGBES Limit is max.65 g/l)

NOTE1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: The above product shall bear the DCL Conformity Mark.

NOTE 3: For colors/types not covered by the Scope, LRV shall be tested and classified based on the application of the product in the construction site to ensure that it meets the requirements of the DM-GBRS.

- LRV Class 1 (≥ 45) – “Can be used in 75-100% of surface to be /painted/coated”
- LRV Class 2 (< 45 or untested) – “Can be used in 0-25% of surface to be painted/coated provided the remaining area is Class 1”.

Original Issue Date : 25 June 2019

Current Issue Date : 25 June 2020

Valid Until : 24 June 2021

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department