

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Pipe and Duct Insulation

(Details as per the attached Scope of Certification)

manufactured by:


SUPERLON WORLDWIDE SDN. BHD.

Lot 2736 Jalan Raja Nong, 41200 Klang Selangor, D.E. Malaysia

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

2017 AL SA'FAT DUBAI GREEN BUILDING EVALUATION SYSTEM

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



001-CB-PRD

Certificate No: CL16020383
Valid Until: 30/07/2021



Current Issue Date: 31/07/2020
Original Issue Date: 31/07/2016



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL16020383

Certificate Issued To : **SUPERLON WORLDWIDE SDN. BHD.**
Lot. 2736, Jalan Raja Nong, 41200 Klang, Selangor D.E.
Malaysia

Applicable Standard Specification : 2017 Al Sa'fat Dubai Green Building Evaluation System

Applicable Specific Rules : DM-DCLD-RD-DP21-2185-(IC) Specific Rules for the
Certification of Pipe and Duct Insulation as per 2017 Al
Sa'fat Dubai Green Building Evaluation System

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1.	NBR Elastomeric Foam for Pipe & Duct Insulation CFC Free (See Note 3)	SUPERLON	NBR Elastomeric Foam manufactured without facing Sizes: (1 m - 1.22 m) x (2 m - 9.14m) Rolls Thickness range: 3 mm to 50 mm Pre-Cut Sheet Thickness range: 3 mm to 38 mm Sizes 1.22 m x. 0.914 m Pipes Internal Diameter: 6 mm to 140 mm Pipe Thickness: 3 mm to 250 mm Thermal Conductivity (max): 0.0376 W/(m-°K) @ 35 °C & 55% RH Water Vapor Permeance is meeting the requirements of Table 1 of BS 5422:2009

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL16020383**

- Note 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.*
- Note 2: The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).*
- Note 3: CFC Free as per declaration from the company, in accordance with the 2017 Al Sa'fat.*

Original Issue Date: 31 July 2016
Current Issue Date: 31 July 2020
Valid Until: 30 July 2021

ARIF HUSAIN AL MARZOOQI
Products Conformity Assessment Section Manager
Dubai Central Laboratory Department