

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Mineral Wool Insulation

(Details as per the attached Scope of Certification)

manufactured by:

HEBEI HUANENG REFRACTORY INSULATION MATERIALS LIMITED BY SHARE LTD
Hejianshi Migezhaung industrial Area, Hejian City, Cangzhou City, Hebei Province, China

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

BS EN 13162: 2012 +A1: 2015

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality



Certificate No: CL19020711
Valid Until: 03/08/2021



Current Issue Date: 04/08/2020
Original Issue Date: 04/08/2019



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020711**

Certificate Issued To

**HEBEI HUANENG REFRACTORY INSULATION
MATERIALS LIMITED BY SHARE LTD.**

Hejianshi Migezhaung industrial Area, Hejian City,
Cangzhou City, Hebei Province, China

Applicable Standard Specification:

BS EN 13162: 2012 +A1: 2015 – Thermal Insulation
Products for Buildings – Factory Made Mineral
Wool (MW) Products

Applicable Specific Rules:

DM-DCLD-RD-DP21-2130 (IC) “Specific Rules for
Certification of Factory Made Mineral Wool Thermal
Insulation Products (as per BS EN 13162: 2012
+A1: 2015) Through Factory Assessment”.

S/N	PRODUCT DESCRIPTION	PRODUCT BRAND	PRODUCT DETAILS
1.	Mineral Wool Thermal Insulation Material (Rockwool) Slab/Board	YILAIMAITE	Mineral Rockwool Board manufactured with Aluminum foil facing on one side Length & Width: 1200 mm x 600 mm Thickness: 30 mm to 150 mm Density = 60 to 200 kg/m ³ Thermal Conductivity: k-value (max) 0.040 W/ (m-K) @ 35°C & 60% RH MW-EN13162-T1-DS(70,90)-CS(10)30- PL(5)200-Zi3

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020711

		YILAIMAITE	<p>Mineral Rockwool Board manufactured without facing</p> <p>Length & Width: 1200 mm x 600 mm</p> <p>Thickness: 30 mm to 150 mm</p> <p>Density = 60 to 200 kg/m³</p> <p>Thermal Conductivity: k-value (max) 0.040 W/(m-K) @ 35°C & 60% RH</p> <p>MW-EN13162-T1-DS(70,90)-CS(10)30- PL(5)200-MU3</p>
2.	Mineral Wool Thermal Insulation Material (Rockwool) Blanket	YILAIMAITE	<p>Mineral Rockwool Blanket manufactured with wire mesh facing on one side</p> <p>Length & Width: 3000 mm x 600 mm</p> <p>Thickness: 30 mm to 80 mm</p> <p>Density = 60 to 120 kg/m³</p> <p>Thermal Conductivity: k-value (max) 0.040 W/(m-K) @ 35°C & 60% RH</p> <p>MW-EN13162-T1-DS(70,90)-CS(10)0.5- Zi3</p>
		YILAIMAITE	<p>Mineral Rockwool Blanket manufactured without facing</p> <p>Length & Width: 3000 mm x 600 mm</p> <p>Thickness: 30 mm to 80 mm</p> <p>Density = 60 to 120 kg/m³</p> <p>Thermal Conductivity: k-value (max) 0.040 W/(m-K) @ 35°C & 60% RH</p> <p>MW-EN13162-T1-DS(70,90)-CS(10)0.5- MU3</p>

DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL19020711**

- Note 1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.*
- Note 2: The above products shall bear the DCL Conformity Mark (applied on each product or on the packaging).*
- Note 3: CFC Free as per declaration from the company, in accordance with Al Sa'fat – Dubai Green Building Evaluation System.*

Original Issue Date: 04 Aug 2019

Current Issue Date: 04 Aug 2020

Valid Until: 03 Aug 2021

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department