

# CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality  
hereby attests that the product(s)

## In-situ Formed Sprayed PUR/PIR Thermal Insulation

(Details as per the attached Scope of Certification)

manufactured by:

### TASHAREEK WATERPROOFING INSULATION LLC

Citadel Tower, Business Bay, Dubai, UAE

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

### BS EN 14315-1: 2013

Accordingly, DCLD hereby authorizes the above manufacturer  
to affix the DCL Product Conformity Mark on the above-mentioned product(s).



for / ENGR. AMIN AHMED AMIN  
Director, Dubai Central Laboratory Department  
Dubai Municipality



Certificate No: CL19020715  
Valid Until: 02/11/2021



Current Issue Date: 03/11/2020  
Original Issue Date: 03/11/2019



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.  
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

DUBAI CENTRAL LABORATORY DEPARTMENT  
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME

SCOPE OF CERTIFICATION  
FOR CERTIFICATE NO. CL19020715

<b>Certificate Issued To:</b>	TASHAREEK WATERPROOFING INSULATION LLC Citadel Tower, Business Bay, Dubai, UAE
<b>Applicable Standard Specification:</b>	BS EN 14315-1:2013 – Thermal Insulating Product for Buildings In-situ Formed Sprayed Rigid Polyurethane (PUR) and PIR Foam Products
<b>Applicable Specific Rules:</b>	DM-DCLD-RD-DP21-2187 (IC) “Specific Rules for Certification of In-Situ Formed Sprayed Polyurethane and Polyisocyanurate Foam Products (as per EN14315-1:2013) Through Factory Assessment”.

S/N	Product Description	Brand Name	Product Details
1	Spray-Applied Rigid Polyurethane (PUR) Foam Products  “CFC Free” *	TASHAREEK WATERPROOFING INSULATION LLC	In-Situ Formed Sprayed Polyurethane (PUR) Foam Minimum Density : 30 kg/m <sup>3</sup> Thickness = 50 mm (±5 mm) K-value: max. 0.028 W/(m.K) at 35°C temperature and 60% relative humidity condition Dimensional Stability DS(TH)1 Short term water absorption by partial immersion: 0.2 kg/m <sup>2</sup> (max) Product Code: PU EN14315-1-DS(TH)1-CS(10/Y)100-MU(25)

NOTE1: This document forms part of the Certificate of Product Conformity bearing the same certificate number.

NOTE2: \*CFC Free as per declaration from the company in accordance with the 2017 Al Sa'fat – Dubai Green Building Evaluation System

Original Issue Date : 03 November 2019

Current Issue Date : 03 November 2020

Valid Until : 02 November 2021

ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager  
Dubai Central Laboratory Department