

**Circular No. (6-1-1) of 2021 AD**

**On 23/8/2021 AD**

**regarding Central Gas Distribution Networks**

**M /s. Engineering Consultancy Offices and Construction Contracting Companies**

**After Greetings,**

Centralized Liquid Natural Gas distribution systems shall be used in all multi-story buildings in accordance with the following controls:

1. The design of the Liquid Natural Gas distribution networks shall be carried out in accordance with the approved engineering specifications and standards and submitted for approval within the drawings submitted with the building licensing transactions.
2. The use of materials and control and reading devices approved by the Civil Defense Department only.
3. It is preferable that the natural gas tank be placed within the boundaries of the land, whether below or above the ground level and at safe distances in accordance with the safety requirements contained in the UAE Fire and Life Safety Code and the requirements of the Civil Defense.
4. The central reservoir shall be provided with the means of security, protection, and control in accordance with the standards specified by the Civil Defense Department.
5. All standards and requirements for public safety shall be adhered to in accordance with the regulations adopted by Dubai Municipality.
6. Domestic gas networks shall be implemented by specialized companies registered to implement this activity in Dubai Municipality.

**“This is a technical translation, in case of ambiguity Arabic version will prevail “**